

BRE Certification Limited and LPCB

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 0794

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

EP203 conventional three zone "class A" extinguisher control panel for use in fire detection and alarm systems

(For conditions of use for the product see the attached appendix)

placed on the market by

**Computationics (Trading as C-TEC)
Stephens Way, Goose Green, Wigan WN3 6PH**

and produced in the factory

**Computationics (Trading as C-TEC)
Stephens Way, Goose Green, Wigan WN3 6PH**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Certification Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

**EN 54 - 2: 1997 + A1: 2006: + A2: 2007 - Fire detection and fire alarm systems - Part 2:
Control and indicating equipment**

**EN 54 - 4: 1997 + A1: 2002 + A2: 2006 - Fire detection and fire alarm systems - Part 4: Power
supply equipment and**

**EN 12094 - 1: 2003 - Fixed firefighting systems - Components for gas extinguishing systems -
Part 1: Requirements and test methods for electrical automatic control and delay devices**
were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 8/8/2008 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.

Paul Stevens

For and on behalf of BRE Certification Limited



Date of Issue: 8/8/2008

Issue Number: 1

Page: 1 of 2

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.

BRE Certification Limited and LPCB

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 0794

The details and conditions of use for the EP203 conventional three zone "class A" extinguisher control panel, placed on the market by Computationics (Trading as C-TEC) Stephens Way, Goose Green, Wigan WN3 6PH are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Incorporating the following units:

SPF0000203	Main extinguisher control
SPF0000212	External relay interface
SPF0003613	Power supply unit
SPF0000214	EP214 terminal

Incorporating as modular units:

EP210S	Remote Status Unit "Surface Mount" optional (See Note 1)
EP211	Economy Status Unit optional (See Note 1)

Certified with the following options with requirements from EN 12094-1:2003

- 4.17 Delay of extinguishing signal
- 4.18 Signal representing the flow of extinguishing agent
- 4.19 Monitoring of the status of components
- 4.20 Emergency hold device
- 4.21 Control of flooding time
- 4.23 Manual only mode
- 4.26 Triggering of equipment outside the system
- 4.27 Emergency abort device
- 4.30 Activation of alarm devices with different signals

Certified with the following options with requirements from EN 54-2:1997

- 7.8 Output to fire alarm device(s)
- 7.11 Delays to the auctioning of outputs fire alarm devices and fire routing equipment
- 7.13 Alarm counter
- 10 Test condition

Note:

- 1) Optional Remote Status Unit part No. EP210S & Economy Status Unit part No. EP211 are not certified as meeting the requirements of the standards specified.
- 2) Meets the requirements of EN12094-3:2003, Class A – i.e. operational temperature range of -5°C to +40°C.

Paul Stevens
For and on behalf of BRE Certification Limited



Date of Issue: 8/8/2008
Issue Number: 1
Page: 2 of 2

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.