



Certificate of Continued Compliance 202350145/AA/00



Issued	20-04-2021	Replaces	
Expiry date	20-04-2025	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	Door Contact / Shock Sensor
Trademark:	Climax
Type designation:	DCSV-29
Hardware / Software:	V1.0A / FM868_00_DCSV-23_P2_F1_EN_TEST_Test3_T11_to_EN

Placed on the market under the name or trademark of:

Name of the manufacturer:	Climax Technology Co., Ltd.
Address:	No. 258, Xinhua 2nd. Road, Neihu District
City:	114 TAIPEI CITY
Country:	Taiwan

This certificate is granted to:

Name of the certificate holder:	Climax Technology Co., Ltd.
Address:	No. 258, Xinhua 2nd. Road, Neihu District
City:	114 TAIPEI CITY
Country:	Taiwan

Ron Scheepers
Managing director

Telefication B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

This certificate has THREE Annexes.



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

Climax Technology Co., Ltd.

No. 258, Xinhua 2nd. Road, Neihu District

TAIPEI CITY

Taiwan

Product inspection location:

Deventer KontraktLogistik GmbH c/o Climax Deutschland GmbH

Hüttenstraße 100

Kerpen

Germany

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 200702041-001-Ver 1.00, 16 April 2021
- Telefication B.V.: 200702041-002-ver.1.00, 16 April 2021

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-6	September, 2008
EN 50131-2-8	December, 2016
EN 50131-5-3	March, 2017

Applied Standards

EN 50131-1+A1+A2	May, 2017
EN 50130-4+A1	October, 2014
EN 50130-5	June, 2011

The product as described in this certificate includes the following type designations

- | | |
|------------------------|--|
| - Product description: | Door Contact / Shock Sensor |
| - Trademark: | Climax |
| - Type designation: | DCSV-29 |
| - Hardware version: | V1.0A |
| - Software version: | FM868_00_DCSV-23_P2_F1_EN_TEST_Test3_T11_to_EN |