



# Certificate of Continued Compliance 202350140/AA/00



Issued 20-11-2020  
Expiry date 19-11-2024

Replaces  
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: PIR Motion Sensor  
Trademark: Climax  
Type designation: IR-31  
Hardware / Software: V1.0 / IR31F8F12WA0\_LAB\_11762

Placed on the market under the name or trademark of:

Name of the manufacturer: Climax Technology Co., Ltd.  
Address: No. 258, Xinhua 2nd. Road, Neihu District  
City: 114 TAIPEI CITY  
Country: Taiwan

This certificate is granted to:

Name of the certificate holder: Climax Technology Co., Ltd.  
Address: No. 258, Xinhua 2nd. Road, Neihu District  
City: 114 TAIPEI CITY  
Country: Taiwan

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

Telefication B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



## Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.  
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

Climax Technology Co., Ltd.

No. 258, Xinhua 2nd. Road, Neihu District

TAIPEI CITY

Taiwan

Product inspection location:

Deventer KontraktLogistik GmbH c/o Climax Deutschland GmbH

Hüttenstraße 100

Kerpen

Germany

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 200702042-001-Ver. 1.00, 20 November 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

|              |                |
|--------------|----------------|
| EN 50131-2-2 | November, 2017 |
| EN 50131-5-3 | March, 2017    |

Applied Standards

|                  |               |
|------------------|---------------|
| EN 50130-5       | June, 2011    |
| EN 50131-6       | October, 2017 |
| EN 50131-1+A1+A2 | May, 2017     |
| EN 50130-4+A1    | October, 2014 |

**The product as described in this certificate includes the following type designations**

- Product description: PIR Motion Sensor
- Trademark: Climax
- Type designation: IR-31
- Hardware version: V1.0
- Software version: IR31F8F12WA0\_LAB\_11762